



NOTE:

1. VALVES ARE NOT TO BE LOCATED IN CURB AND GUTTER AREA
2. VALVE BOXES ARE REQUIRED AT EACH VALVE LOCATION
3. VALVE BOXES CONSIST OF 6" ASTM 3034 PVC RISER AND 18" CAST IRON 910 COVER
4. MAXIMUM SPACING FOR VALVES IS 500 FEET
5. ALL VALVES ARE TO CONFORM WITH AWWA STANDARDS
6. GATE VALVES ARE REQUIRED FOR 8" AND SMALLER PIPE.
7. BUTTERFLY VALVES ARE REQUIRED FOR 12" AND LARGER PIPE.



ENGINEERING DEPARTMENT  
13125 S.W. HALL BLVD.  
TIGARD, OREGON 97223  
VOICE: (503) 639-4171  
FAX: (503) 684-7297

APPROVED BY:  
AGUSTIN P. DUENAS

CITY ENGINEER

MARCH 1998

APPROVAL DATE

TYPICAL VALVE  
AND HYDRANT LOCATION

NO SCALE

DWG. NO.

575